



Product Service

# CERTIFICATE

No. Z2 087869 0004 Rev. 00

**Holder of Certificate:** **APPROSUD ENVIRONNEMENT SAS**  
27 RUE PIERRE DE FERMAT  
11200 LEZIGNAN CORBIERES  
FRANCE

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262331901-00

**Valid until:** 2028-08-28

**Date,** 2024-01-18

( Zhulin Zhang )



# CERTIFICATE

No. Z2 087869 0004 Rev. 00

**Model(s):**

SLxxx-M10-FB (xxx=480-515, in steps of 5)  
 SLxxx-M10-54PFB (xxx=380-420, in steps of 5)  
 SLxxx-M10-54PCN (xxx=380-420, in steps of 5)  
 SLxxx-M10-72PCN (xxx=535-560, in steps of 5)  
 xxx is standing for rated output power at STC

**Parameters:**

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P.R.China.
Construction:	Framed or frameless, with Junction box, Cable and connectors.

**Tested according to:**

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06